








S.No	Date	Nature of work	Observation/Remark	Signature PMC AEE/AE QA/QC
1	12/09/2022	Masonry work for First Floor	Curing was not Done Properly. Instructed to Do proper Curing for Walls.	
2	21/09/2022	Shuttering work for First Floor Slab	Joints were not Filled Properly. Instructed to Fill the Joint Gaps with Foam Sheet & Cement Mortar.	
3	23/09/2022	Reinforcement work in progress.	Instructed to Do the Lapping of Rods properly.	
4	26/09/2022	Concreting for First Floor Slab	Instructed for proper Vibration	

Sl. No	Date	Nature of Work	Observation/Remarks	Signature
5	17/10/2022	Shuttering work for Second floor Slab.	Instructed to fill the Gaps between Sheets using Foam Sheets.	
6	21/10/2022	Reinforcement work for Second Floor Slab.	Instructed for Proper laping of Rods.	
7	23/10/2022	Second floor Slab Concrete work.	Instruction given for the proper Use of Vibrator.	

Sl.No	Date	Sample Collected	Test Conducted	Results / Remarks	Signature
1	28/08/2022	Fine Aggregate Sample Collection	Sieve Analysis & Sp. Gravity	Satisfactory	<i>[Signature]</i>
2	28/08/2022	Coarse Aggregate Sample Collection.	Sieve Analysis, FI, EI, Sp. Gr, Bulk Density, Water Absorption, ACV, AIV.	Satisfactory	<i>[Signature]</i>
3	28/08/2022	Reinforcement Steel Sample Collection.	Physical & Chemical properties	Satisfactory	<i>[Signature]</i>
4	28/08/2022	Cement Sample Collection.	Compressive St & Final & Initial Setting Time	Satisfactory	<i>[Signature]</i>
6	07/09/2022	Cubes Casting for Column Concreting	Compressive Strength for 7 & 28 Days	Satisfactory	<i>[Signature]</i>

Sl. No	Date	Sample Collected	Test Conducted	Results / Remarks	Signature
7	26/09/2022	Cube Casting at Site for First Floor Slab	Compressive Strength for 7 & 28 Days.	Satisfactory	<i>[Signature]</i>
8	30/09/2022	Cube Casting for Column Concreting	Compressive Strength for 7 & 28 Days.	Satisfactory	<i>[Signature]</i>
9	23/10/2022	Cube Casting for Slab Concreting	Compressive Strength for 7 & 28 Days.	Satisfactory	<i>[Signature]</i>